



Product Service

Attestation of Conformity

No. N8A 107662 0051 Rev. 00

Holder of Attestation: **FOXESS CO., LTD.**

No.939, Jinhai Third Road
New Airport Industry Area, Longwan District
325058 Wenzhou, Zhejiang
PEOPLE'S REPUBLIC OF CHINA

Product: **Batteries**
(Rechargeable Li-ion Battery System)

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2014/35/EU relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for conformity assessment. For details see: www.tuvsud.com/ps-cert

Test report no.: 64280256026501

Date, 2025-10-02

(Harry Zhang)

Page 1 of 3

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.



Product Service

Attestation of Conformity

No. N8A 107662 0051 Rev. 00

Model(s): CQ 48.21, CQ 64.28, CQ 80.35, CQ 96.42,
CQ 112.49, CQ 128.56, CQ 144.63,
CQ 160.70, CQ 176.77, CQ 192.84,
CQ 208.91, CQ 224.98, CQ 241.05

Brand: FOXESS



Parameters:

Nominal Voltage:	CQ 48.21: 153.6 Vd.c. CQ 64.28: 204.8 Vd.c. CQ 80.35: 256.0 Vd.c. CQ 96.42: 307.2 Vd.c. CQ 112.49: 358.4 Vd.c. CQ 128.56: 409.6 Vd.c. CQ 144.63: 460.8 Vd.c. CQ 160.70: 512.0 Vd.c. CQ 176.77: 563.2 Vd.c. CQ 192.84: 614.4 Vd.c. CQ 208.91: 665.6 Vd.c. CQ 224.98: 716.8 Vd.c. CQ 241.05: 768.0 Vd.c.
Rated Capacity:	314 Ah
Rated Energy:	CQ 48.21: 48.21 kWh CQ 64.28: 64.28 kWh CQ 80.35: 80.35 kWh CQ 96.42: 96.42 kWh CQ 112.49: 112.49 kWh CQ 128.56: 128.56 kWh CQ 144.63: 144.63 kWh CQ 160.70: 160.70 kWh CQ 176.77: 176.77 kWh CQ 192.84: 192.84 kWh CQ 208.91: 208.91 kWh CQ 224.98: 224.98 kWh CQ 241.05: 241.05 kWh
Ingress Protection:	IP20
Protective Class:	Class I

Page 2 of 3

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.



Product Service

Attestation of Conformity

No. N8A 107662 0051 Rev. 00

**Tested
according to:**

EN 62477-1:2012/A12:2021

Page 3 of 3

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.